

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1095 | m-20 | 1 | 26

Dated : 6/5/26

It is certified that an inspection team headed by En. Rameshwar Dayal [Ex. Engineer] (Name of Officer with Designation) From Uttar Pradesh Jal Nigam (Rural), Mau (Name of Department/ Office) inspected the Central Public School, Maryadpur, Mau (Name & Address of the School) on 06/05/2026 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No. T.C./MAU/26/32 dated 06/05/2026 of District level water Lab (PHED Lab) certified that the Central Public School, Maryadpur (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature with Seal :

Name :

Designation :

Name & Address of the office / Department:

Executive Engineer
Division Office
U.P. Jal Nigam (Rural)
Mau

To,

Central public SchoolMaryadpurMau (U.P.)

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Water Analysis Report



District Level Water Analysis Laboratory

UP Jal Nigam (Rural) - Mau

Office of the Executive Engineer, Division office

UP Jal Nigam (Rural), Mau- 275101



TC-16812

Report No.: TC/MAU/26/32

Date: 06.05.2026

Page No.: 1

Customer Details

Office Name and Address Central Public School, Maryadpur- Mau

Basic Details of Sample

District		Mau		Block		Fatehpur Mandaon
Habitation		School campus		Location		Maryadpur
Water Source		RO		Sample Code		MAU/26/05/01
Quantity of Sample		1000 ml (Normal)		Sampling date		06.05.2026
Sample Received Date		06.05.2026		S. collected by		Abhishek Yadav
Sampling Method Used		As per SOP		Sample Depositor		Abhishek Yadav
Analysis Start Date		06.05.2026		Analysis Completion date		06.05.2026
Temperature(°C)		26°C		Humidity (%)		50%
S. No.	Analyzed Parameters	Unit	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1.	Colour	(Hazen)	<5	5	15	APHA 24th Edition-2120
2.	pH	-	7.69	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022
3.	Turbidity	NTU	0	1	5	IS 3025 (Part 10):2023
4.	Total Dissolved Solids	mg/l	262	500	2000	IS 3025 (Part 16): 2024
5.	Total Hardness (as CaCO3)	mg/l	120	200	600	IS 3025 (Part 21): 2023
6.	Calcium (as Ca)	mg/l	16.0	75	200	IS 3025 (Part 40): 2019
7.	Magnesium (as Mg)	mg/l	12.3	30	100	IS 3025 (Part 46): 2024
8.	Chloride (as Cl)	mg/l	31.9	250	1000	IS 3025 (Part 32): 2019
9.	Total Alkalinity (as CaCO3)	mg/l	108	200	600	IS 3025 (Part 23): 2023
10.	Taste	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8): 2023
11.	Odour	-	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018

Note:

1. This certificate refers only to the particular sample(s) submitted for analysis.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
5. Parameters above Permissible Limit are written in **bold**. (BDL=Below detection limit)
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
7. Sample is not Collected by Lab.

Laboratory Contact detail: email: labmaunath@gmail.com, Mob. 6307933383



****END OF THE ANALYSIS REPORT****